



THE NATIONAL BOARD

OF BOILER AND PRESSURE VESSEL INSPECTORS

August 25, 2016

Bogdan Matysek
F. C. Kingston Company
23201 Normandie Avenue
Torrance, CA 90501

**Subject: Capacity Certification, Valve Type: 118C & 119 (.302" Orif.)
NB Cap Cert. No.: KNG-M35086**

Dear Mr. Matysek,

We have reviewed the test results referenced below which were performed at the **National Board Testing Laboratory** on August 17, 2016 for the purpose of testing for capacity certification of the subject valve type as required by paragraph UG-136(c)(3) of Section VIII of the ASME Code.

F.C. Kingston Company is hereby granted capacity certification and authorization to apply the "NB" mark and ASME Certification mark with "UV" designator to the valve type listed in the scope of certification. This authorization is valid only for the above location and only while the organization is fully implementing its quality control system as accepted by the National Board.

SCOPE OF CERTIFICATION

Valve Type: 118C & 119 (.302" Orif.)

Organization Type: Manufacturer

Certified Rating Value/Sizes/Pressure Ranges: As listed in the NB-18

Certification Expiration Date: December 18, 2022

Sincerely,

Ryan Ford,
Senior Staff Engineer, Pressure Relief Dept.

REFERENCING TEST NUMBERS: 42771A, 42772A

File: RF: 160825 KNG-M35086 Pass